

## INSULATING GLOVES

### LEATHER PROTECTORS, FABRIC LINERS, AND GLOVE BAG

#### 1. GENERAL

**1.001** This addendum supplements Section 460-300-103, Issue 3. Place this pink sheet ahead of Page 1 of the section.

**1.002** This addendum is issued to add:

- Information to paragraph 7.04 on inspection of rubber insulating gloves
- Information on inner ply color of insulating gloves.

#### 2. CHANGES TO SECTION

**2.001** On Page 2, revise paragraph 3.04 as follows:

**3.04** The E insulating gloves are made of two plies of rubber: the outer ply black and the inner ply either red or yellow, to aid in determining the physical condition of the glove. Leather protector gloves must be worn over these gloves when in use. They are intended for use by outside plant forces.

**2.002** On Page 2, revise paragraph 3.05 as follows:

**3.05** The F insulating gloves are made of two plies of rubber, the inner ply either red or

yellow and the outer ply black, as an aid in visual inspection. They are of such thickness as not to require protector gloves when used in central offices. However, when used in the outside plant, the proper size D leather protector gloves must be used. The F insulating gloves are marked as shown in Table C.

**2.003** On Page 6, revise paragraph 7.04 as follows but retain subparagraphs (1) through (3):

(4) Inspect the gloves over the entire surface (inside and out). Roll the rubber gently between the hands to expose defects, embedded foreign matter, and solvent or oil damage.

(5) The air test should be performed last (see paragraphs 8.01 and 8.02).

**2.004** On Page 6, revise paragraph 7.05 as follows:

**7.05** When performing the previous tests with the two-color D, E, and F insulating gloves, the appearance of red or yellow ply showing through the black means the glove is defective and not safe to use. It shall be disposed of in accordance with local instructions.

#### NOTICE

Not for use or disclosure outside the  
Bell System except under written agreement